

RFP#2024-04WFS

Questions #2

1. Typically, when the fire alarm system is modified, the entire system must be brought up to current code. That could mean reworking the entire facility including the church. There may be a possibility that the Fire Marshall/Building Department has waived this requirement and no upgrades are required. Please confirm with the facility staff regarding feedback they have received from the Fire Marshall and building department.

Answer: We are not required to upgrade the fire alarm system at this time. The only requirement is to install a fire sprinkler system per the specifications outlined in the RFP.